




# 2023 Annual Drinking Water Quality Report (Consumer Confidence Report)



## Our Drinking Water is Regulated

The City of Victoria's water system has been given a "Superior" rating by the Texas Commission on Environmental Quality. This means that it either meets or exceeds all State and Federal water quality standards and that there is ample supply, storage, and pumping facilities to meet the citizens' needs.

This report is a summary of the quality of the water we provide our customers for the period of January 1, 2023, to December 31, 2023. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what is in your drinking water.

## Information about your Drinking Water

### Drinking Water Sources

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

When drinking water meets federal standards, there may not be any health based benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the Surface Water Treatment Plant Manager at 361.485.3415.

### Special Notice

#### **Required Language for All Community Public Water Supplies**

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

### En Español

Este reporte incluye la información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (361) 485-3381 par hablar con una personal bilingüe en español.

### Where Do We Get Our Drinking Water?

The City of Victoria's primary source is 20,000-acre feet of surface water from the Guadalupe River. This is about two times the amount of water that the City currently uses. This water is made available through a permit issued by the Texas Commission on Environmental Quality, (TCEQ). Because there are environmental restrictions placed on this permit and because there are senior water rights downstream of the City, there may be times during extreme drought situations when the City could not get all of the water that it needs from this source.

Therefore, in addition to the Guadalupe River water, the city has off-channel reservoirs holding 3,000-acre feet of water located on 640 acres of incorporated land. This water is a mixture of groundwater from a shallow aquifer and Guadalupe River water that the city has pumped into these reservoirs.

Lastly, the City of Victoria has retained 10 water wells for extreme emergencies and for peak demand periods. These wells are drilled into the Gulf Coast Aquifer and prior to 2001 they supplied all the water for the City's residents.

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detection of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact the Surface Water Treatment Plant Manager at (361) 485-3415.

## About the Following Pages

The pages that follow list all of the federally regulated or monitored contaminants which have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants. Although some of these components were detected in your water, none of them exceeded the Maximum Contaminant Level. The EPA and the TCEQ mandate that each community water system provide its customers with an annual Consumer Confidence Report. Much of the language contained in this report is required.

## Public Participation Opportunities

You are invited to comment on this information during the Citizen Communication portion of any regularly scheduled City Council meeting. These meetings are held at 5:00 p.m. on the first and third Tuesdays of each month in the City Council Chambers, 107 W. Juan Linn Street, Victoria, Texas. To learn about future public meetings (concerning your drinking water), or to request one, please call us at (361) 485-3381.

## Definitions Used in This Report

### **Definitions and Abbreviations**

**The following tables contain scientific terms and measures, some of which may require explanation.**

<b>Action Level:</b>	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
<b>Avg:</b>	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
<b>Maximum Contaminant Level or MCL:</b>	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
<b>Maximum Contaminant Level Goal or MCLG:</b>	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
<b>Maximum residual disinfectant level or MRDL:</b>	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
<b>Maximum residual disinfectant level goal or MRDLG:</b>	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
<b>MFL</b>	million fibers per liter (a measure of asbestos)
<b>mrem:</b>	millirems per year (a measure of radiation absorbed by the body)
<b>na:</b>	not applicable.
<b>NTU</b>	nephelometric turbidity units (a measure of turbidity)
<b>pCi/L</b>	picocuries per liter (a measure of radioactivity)
<b>ppb</b>	micrograms per liter or parts per billion
<b>ppm</b>	milligrams per liter or parts per million

## 2023 Regulated Contaminants Detected

### Total Coliform

Total coliform bacteria are used as indicators of microbial contamination of drinking water because testing for them is easy. While not disease-causing organisms themselves, they are often found in association with other microbes that are capable of causing disease. Coliform bacteria are more hardy than many disease-causing organisms; therefore, their absence from water is a good indication that the water is microbiologically safe for human consumption.

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	5% of monthly samples are positive	4.6	0	0	N	Naturally present in the environment

### Lead and Copper

Required Additional Health Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Victoria is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# of Sites Over AL	Units	Violation	Likely Source of Contamination
<b>Lead*</b>	2023	0	15	0.000	1	ppb	N	Corrosion of household plumbing systems; erosion of natural deposits.
<b>Copper*</b>	2023	1.3	1.3	0.292	0	ppm	N	Erosion of natural deposits; leaching from wood preservatives; corrosion of household plumbing systems.

\***Lead and Copper** – Next required analysis will be taken in 2026. Testing is required every three (3) years.

## Maximum Residual Disinfectant Level

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit Of Measure	Violation (Y/N)	Source in Drinking Water
Total Chlorine	2023	2.4	0.3 – 3.70	4	4	mg/L	N	Water additive used to control microbes

## Regulated Contaminants

### Disinfectants and Disinfection By-Products

Disinfection By-Products	Collection Date	Highest Level or Avg Detected	Range of Individual Samples	MCLG	MCL	Unit	Violation	Likely Source of Contamination
Haloacetic Acid (HAA5)*	2023	29	3.5 – 58.3	No goal for the total	60	ppb	N	By-product of drinking water chlorination
Total Trihalomethanes (TTHm)*	2023	66	35.9 – 86.5	No goal for the total	80	ppb	N	By-product of drinking water chlorination
Chlorite	2023	0.82	0.107 -0.82	0.8	1	ppm	N	By-product of drinking water chlorination

\*The value in the Highest Level or Avg Detected Column is the highest average of all HAA5 & TTHM sample results collected at a location over a year.

## Inorganic Contaminants

Contaminant	Collection Date	Highest Level or Avg. Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	2023	3	2.8 - 2.8	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production waste
Barium	2023	0.0698	0.0698 - 0.0698	2	2	ppm	N	Discharging of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Cyanide*	2023	<0.01	<0.01 - <0.01	200	200	ppb	N	Discharge from plastic, fertilizer, steel/metal factories
Chromium	2023	<0.01	<0.01	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride	2023	0.2	0.22 - 0.22	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; discharge from fertilizer and aluminum
Nitrate (Measured as Nitrogen)	2023	0.09	0.09 - 0.09	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Selenium	2023	<0.003	<0.003	50	50	ppm	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
Thallium	2023	<0.0004	<0.0004	0.5	2	ppm	N	Discharge from electronics, glass and leaching from ore-processing sites; drug factories

\*Next required analysis will be taken in 2026. Testing is required every three (3) years.

## Radioactive Contaminants

Radioactive Contaminants	Collection Date	Highest Level or Average Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228*	2023	<1.0	<1.0	0	5	pCi/L	N	Erosion of natural deposits

\*Next required analysis will be taken in 2026. Testing is required every six (6) years.

## Turbidity

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
Highest Single Measurement	1 NTU	0.29 NTU	N	Soil Runoff
Lowest Monthly % Meeting Limit	0.3 NTU	100.00%	N	Soil Runoff

## Total Organic Carbon (TOC)

Total organic carbon (TOC) has no health effects. The disinfectant can combine with TOC to form disinfectant by-products. Disinfection is necessary to ensure that water does not cryptosporidium have unacceptable levels of pathogens. By-products of disinfection include trihalomethanes (THMs) and haloacetic acids (HAA) which are reported elsewhere in this report.

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set.

Year	Contaminant	Average Level	Minimum Level	Maximum Level	Unit of Measure	Source of Contaminant
2023	Source Water	4.3	2.3	10.0	ppm	Naturally present in the environment
2023	Drinking Water	2.6	2.0	3.5	ppm	Naturally present in the environment
2023	Removal Ratio	46.51	<1	80	%*	N/A

\*Removal ratio is the percent of TOC removed by the treatment Process divided by the percent of TOC required by TCEQ to be removed.

## Synthetic Organic Contaminants

Regulated Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contaminant
Atrazine	2023	<0.1	0.1 - 0.1	3	3	ppm	N	Runoff from herbicide used on row crops
Di (2-ethylhexyl) Phthalate	2023	<0.6	0 - <0.6	0	6	ppm	N	Discharge from rubber and chemical factories

## Unregulated Contaminants

Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Year or Range	Contaminant	Average Level	Minimum Level	Maximum Level	Unit of Measure	Source of Contaminant
2023	Chloroform	12.90	5.3	23.3	ppb	By-product of drinking water disinfection
2023	Bromoform	5.53	3.3	8.9	ppb	By-product of drinking water disinfection
2023	Bromodichloromethane	21.22	11.3	28.2	ppb	By-product of drinking water disinfection
2023	Dibromochloromethane	23.15	14.1	34.2	ppb	By-product of drinking water disinfection

## Secondary and other Constituents Not Regulated (No associated adverse health effects)

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color, or odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not EPA. These constituents are not causes for health concern. Therefore, secondaries are not required to be reported in this document, but they may greatly affect the appearance and taste of your water.

Year	Constituent	Average Level	Minimum Level	Maximum Level	Secondary Limit	Unit of Measure	Source of Constituent
2023	Aluminum	.0639	.0639	.0639	0.2	ppm	Abundant naturally occurring element
2023	Bicarbonate	187	187	187	NA	ppm	Corrosion of carbonate rocks such as limestone
2023	Calcium	49.1	49.1	49.1	NA	ppm	Abundant naturally occurring element
2023	Chloride	59	59	59	300	ppm	Abundant naturally occurring element; used in water purification; byproduct of oil field activity
2023	Copper	0.0326	0.0326	0.0326	1	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
2023	Hardness as Ca/Mg	184	184	184	NA	ppm	Naturally occurring calcium and magnesium
2023	Magnesium	14.8	14.8	14.8	NA	ppm	Abundant naturally occurring element
2023	Manganese	<0.001	<0.001	<0.001	N/A	ppm	Abundant naturally occurring element
2023	Nickel	0.0018	0.0018	0.0018	NA	ppm	Erosion of natural deposits
2023	pH	8.1	8.1	8.1	>7.0	units	Measure of corrosivity of water
2023	Sodium	43.2	43.2	43.2	NA	ppm	Erosion of natural deposits; byproduct of oil field activity
2023	Sulfate	24	24	24	300	ppm	Naturally occurring; common industrial byproduct; byproduct of oil field activity
2023	Total Alkalinity as CaCO <sub>3</sub>	153	153	153	NA	ppm	Naturally occurring soluble mineral salts
2023	Total Dissolved Solids	308	308	308	1000	ppm	Total dissolved mineral constituents in water
2023	Zinc	0.148	0.148	0.148	5	ppm	Moderately abundant naturally occurring element; used in the metal industry



**Public Works Department**, 700 Main Center, Suite 107  
P.O. Box 1758, Victoria, Texas 77902-1758  
(361) 485-3381, Fax (361) 485-3385

**Ken Gill, Director, P.E.**

## **IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

### **Monitoring Requirements Not Met for City of Victoria – TX2350002**

Our system failed to collect every required coliform sample. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did (are doing) to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether our drinking water meets health standards. During the time period of December 1, 2023 – December 31, 2023, we did not complete all required testing for coliform bacteria and therefore cannot be sure of the quality of your drinking water during that time.

#### **What should I do?**

There is nothing you need to do at this time. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, we are required to notify you within 24 hours.

#### **What is being done?**

Since this event, we have updated our site sampling plan to include an additional 10 samples per month. Once this procedural change was implemented; we collected every required coliform sample in January 2024 and are no longer in violation.

For more information, please contact Kevin Post, Surface Water Treatment Plant Manager at 361-485-3381 or 702 N Main, Suite 107, Victoria, TX 77901.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by City of Victoria, Texas. Public Water System ID# TX2350002.

Date distributed: June 1 – June 30, 2024