



MISSION:
TO EXCEL IN
FIRE PREVENTION,
EDUCATION, AND
INVESTIGATIONS

Fire Marshal's Office
9508 NE Zac Lentz
Parkway

VICTORIA, TX 77904
PHONE (361) 485-3460
FAX (361) 485-3476
www.victoriatx.gov

3. To store, handle, or use Class IIIB liquids in tanks or portable tanks for fueling motor vehicles at motor fueling dispensing facilities or where connected to fuel-burning equipment.
Exception: Fuel oil and used motor oil used for space heating or water heating
4. To remove Class I or II liquids from an underground storage tank used for fueling motor vehicles by any means other than the approved, stationary on-site pumps normally use for dispensing purposes.
5. To operate tank vehicles, equipment, tanks, plants, terminals, wells, fuel-dispensing stations, refineries, distilleries, and similar facilities where flammable and combustible liquids are produced, processed, transported, stored, dispensed, or used.
6. To place temporarily out of service (for more than 90 days) an underground, protected above-ground, or above-ground flammable or combustible liquid tank.
7. To change the type of contents stored in a flammable or combustible liquid tank to a material that poses a greater hazard than what the tank was designed and constructed.
8. To manufacture, process, blend, or refine flammable or combustible liquids.
9. To engage in the dispensing of liquid fuels into the fuel tanks of motor vehicles at commercial, industrial, governmental, or manufacturing establishments, or to engage in on-demand mobile fueling operation.
10. To utilize a site for the dispensing of liquid fuels from tank vehicles into the fuel tanks of motor vehicles, marine craft, and other special equipment at commercial, industrial, governmental, or manufacturing establishments, or to engage in on-demand mobile fueling operation.

Installation or removal of a storage tank is \$75.00 per tank. Installation of fuel dispensers is \$25.00 per dispenser.

Hazardous Materials (Section 105.5.22) – an operational permit is required to store, transport on site, dispense, use, or handle hazardous materials in excess of the amounts listed in Table 105.5.22.

Type of Material	Amount
Combustible Liquids	See Section 105.5.18



MISSION:
TO EXCEL IN
FIRE PREVENTION,
EDUCATION, AND
INVESTIGATIONS

Fire Marshal's Office
9508 NE Zac Lentz
Parkway

VICTORIA, TX 77904
PHONE (361) 485-3460
FAX (361) 485-3476
www.victoriatx.gov

Corrosive Materials		
	Gases	See Section 105.5.9
	Liquids	55 gallons
	Solids	1,000 pounds
Explosive Materials		
See Section 105.5.16		
Flammable Materials		
	Gases	See Section 105.5.9
	Liquids	See Section 105.5.18
	Solids	100 pounds
Highly Toxic Materials		
	Gases	See Section 105.5.9
	Liquids	Any Amount
	Solids	Any Amount
Organic Peroxides		
Liquids	Class I	Any Amount
	Class II	Any Amount
	Class III	1 gallon
	Class IV	2 gallons
	Class V	No permit required
Solids	Class I	Any Amount
	Class II	Any Amount
	Class III	10 pounds
	Class IV	20 pounds
	Class V	No permit required
Oxidizing Materials		
Gases		See Section 105.5.9
Liquids	Class 4	Any Amount
	Class 3	1 gallon *
	Class 2	10 gallons
	Class 1	55 gallons
Solids	Class 4	Any Amount
	Class 3	10 pounds *
	Class 2	100 pounds
	Class 1	500 pounds
Pyrophoric Materials		



MISSION:
TO EXCEL IN
FIRE PREVENTION,
EDUCATION, AND
INVESTIGATIONS

	Gases	Any Amount
	Liquids	Any Amount
	Solids	Any Amount
Toxic Materials		
	Gases	See Section 105.5.9
	Liquids	10 gallons
	Solids	100 pounds
Unstable (Reactive) Materials		
	Liquids	
	Class 4	Any Amount
	Class 3	Any Amount
	Class 2	5 gallons
	Class 1	10 gallons
	Solids	
	Class 4	Any Amount
	Class 3	Any Amount
	Class 2	50 pounds
	Class 1	100 pounds
Water-Reactive Materials		
	Liquids	
	Class 3	Any Amount
	Class 2	5 gallons
	Class 1	55 gallons
	Solids	
	Class 3	Any Amount
	Class 2	50 pounds
	Class 1	500 pounds

Fire Marshal's Office
9508 NE Zac Lentz
Parkway

HPM Facilities (Section 105.5.23) – an operational permit is required to store, handle, or use hazardous production materials (semiconductor manufacturing)

High-Piled Storage (section 105.5.24) – an operational permit is required to use a building or portion thereof with more than 500 square feet, including aisles, of high-piled combustible storage. High-piled combustible storage is typically greater than 12 feet above floor but can be as low as 6 feet depending on the material being stored.

Hot Work Operations (Section 105.5.25) – an operational permit is required for hot work operations including, but not limited to:

1. Public exhibitions and demonstrations where hot work is conducted.

VICTORIA, TX 77904
PHONE (361) 485-3460
FAX (361) 485-3476
www.victoriatx.gov